

Facility Summary in Stillwater County in the City of Absarokee

Location: ROCKIN J  
2993 MT Hwy 78  
Absarokee, MT 59001 Stillwater

System Facility ID:56-13932

Facility Code: 30602  
Last Inspected On: 03/16/2020  
Operating Permit Renewal Date: 07/15/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Automatic Car Wash Inc

Operator Contact: Julie Lindgren 4064463123

Owner/Operator: Automatic Car Wash Inc

Julie Lindgren, UST Class A Operator  
Julie Lindgren, UST Class B Operator

|             |                  |                    |    |                          |            |                               |   |                          |                               |                |                |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|----------------|
| Tank Code   | 01               | Tank Age           | 23 | Tank Installed Date      | 05/01/1999 | Tank Material                 | Steel Clad                                | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve  |
| Tag Number  | 4038             | Spill Test Date    |    | Piping Installed Date    |            | Tank Construction             | Double-Walled                             | Piping Construction      | None                          | AST            | No             |
| Tank Status | Currently in Use | MLLD Test Date     |    | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector             | Piping Type              | Pressurized                   | CP Met Types   | Non-corrodible |
| Product     | Diesel           | PLLD Test Date     |    | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No             |
| Capacity    | 2000             | ATG Test Date      |    | Line Tightness Test Date | 10/14/2019 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No             |
|             |                  | Overfill Test Date |    |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                               |                |                |
| Tank Code   | 02               | Tank Age           | 23 | Tank Installed Date      | 05/01/1999 | Tank Material                 | Steel Clad                                | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve  |
| Tag Number  | 4039             | Spill Test Date    |    | Piping Installed Date    |            | Tank Construction             | Double-Walled                             | Piping Construction      | None                          | AST            | No             |
| Tank Status | Currently in Use | MLLD Test Date     |    | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector             | Piping Type              | Pressurized                   | CP Met Types   | Non-corrodible |
| Product     | Diesel           | PLLD Test Date     |    | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No             |
| Capacity    | 4000             | ATG Test Date      |    | Line Tightness Test Date | 11/05/2019 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No             |
|             |                  | Overfill Test Date |    |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                               |                |                |
| Tank Code   | 03               | Tank Age           | 23 | Tank Installed Date      | 05/01/1999 | Tank Material                 | Steel Clad                                | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve  |

|             |                  |                    |            |                          |            |                               |   |                          |                               |                |                |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|----------------|
| Tag Number  | 4040             | Spill Test Date    |            | Piping Installed Date    |            | Tank Construction             | Double-Walled                             | Piping Construction      | None                          | AST            | No             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector             | Piping Type              | Pressurized                   | CP Met Types   | Non-corrodible |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No             |
| Capacity    | 6000             | ATG Test Date      |            | Line Tightness Test Date | 12/03/2019 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No             |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                               |                |                |
| Tank Code   | 04               | Tank Age           | 23         | Tank Installed Date      | 05/01/1999 | Tank Material                 | Steel Clad                                | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve  |
| Tag Number  | 4041             | Spill Test Date    | 05/20/2020 | Piping Installed Date    |            | Tank Construction             | Double-Walled                             | Piping Construction      | None                          | AST            | No             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector             | Piping Type              | Pressurized                   | CP Met Types   | Non-corrodible |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No             |
| Capacity    | 4000             | ATG Test Date      |            | Line Tightness Test Date | 12/07/2019 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No             |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                               |                |                |
| Tank Code   | 05               | Tank Age           | 23         | Tank Installed Date      | 05/01/1999 | Tank Material                 | Steel Clad                                | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve  |
| Tag Number  | 4042             | Spill Test Date    |            | Piping Installed Date    |            | Tank Construction             | Double-Walled                             | Piping Construction      | None                          | AST            | No             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector             | Piping Type              | Pressurized                   | CP Met Types   | Non-corrodible |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No             |
| Capacity    | 8000             | ATG Test Date      |            | Line Tightness Test Date | 11/02/2019 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No             |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                               |                |                |

**Facility Summary in Stillwater County in the City of Columbus**

**Location:** FARMERS UNION TRADING CO  
101 S Pratten St  
Columbus, MT 59019-0509 Stillwater

**System Facility ID:**48-03409

**Facility Code:** 28554  
**Last Inspected On:** 07/11/2022  
**Operating Permit Renewal Date:** 10/31/2025

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Trading Co Columbus

4067800660

Operator Contact: Jennifer Calovis

4067800660

Owner/Operator: Farmers Union Trading Co Columbus

Clarence McCade, UST Class B Operator  
Jennifer Calovis, UST Class A Operator  
Jennifer Calovis, UST Class B Global Operator

|             |                  |                    |            |                          |            |                               |   |                          |                               |                |                  |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|------------------|
| Tank Code   | 10               | Tank Age           | 30         | Tank Installed Date      | 10/01/1992 | Tank Material                 | Cathodically Protected Steel                    | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 1033             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | None                          | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                   | Piping Type              | Pressurized                   | CP Met Types   | Galvanic         |
| Product     | Gasoline         | PLLD Test Date     | 07/11/2022 | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                      | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No               |
| Capacity    | 5500             | ATG Test Date      | 07/11/2022 | Line Tightness Test Date | 07/10/2022 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No               |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco/EMC Basic;Veeder Root/8484 Series PLLD |                          |                               |                |                  |
| Tank Code   | 11               | Tank Age           | 30         | Tank Installed Date      | 10/01/1992 | Tank Material                 | Cathodically Protected Steel                    | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 1034             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | None                          | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                   | Piping Type              | Pressurized                   | CP Met Types   | Galvanic         |
| Product     | Diesel           | PLLD Test Date     | 07/11/2022 | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                      | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No               |
| Capacity    | 2500             | ATG Test Date      | 07/11/2022 | Line Tightness Test Date | 01/09/2022 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No               |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco/EMC Basic;Veeder Root/8484 Series PLLD |                          |                               |                |                  |
| Tank Code   | 12               | Tank Age           | 30         | Tank Installed Date      | 10/01/1992 | Tank Material                 | Cathodically Protected Steel                    | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 1035             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | None                          | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                                    | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic         |

|             |                  |                    |            |                          |            |                               |   |                          |                               |                |                  |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|------------------|
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                      | Primary Pipe Detection   |                               | Vapor Recovery | No               |
| Capacity    | 2500             | ATG Test Date      | 07/11/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No               |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco/EMC Basic                              |                          |                               |                |                  |
| Tank Code   | 14               | Tank Age           | 24         | Tank Installed Date      | 07/01/1998 | Tank Material                 | Cathodically Protected Steel                    | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 1037             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | None                          | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                   | Piping Type              | Pressurized                   | CP Met Types   | Galvanic         |
| Product     | Gasoline         | PLLD Test Date     | 07/11/2022 | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                      | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No               |
| Capacity    | 10000            | ATG Test Date      | 07/11/2022 | Line Tightness Test Date | 01/13/2022 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No               |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco/EMC Basic;Veeder Root/8484 Series PLLD |                          |                               |                |                  |
| Tank Code   | 13               | Tank Age           | 24         | Tank Installed Date      | 07/01/1998 | Tank Material                 | Cathodically Protected Steel                    | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 4731             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | None                          | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                   | Piping Type              | Pressurized                   | CP Met Types   | Galvanic         |
| Product     | Diesel, Dyed     | PLLD Test Date     | 07/11/2022 | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                      | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No               |
| Capacity    | 10000            | ATG Test Date      | 07/11/2022 | Line Tightness Test Date | 04/10/2022 | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                               | Energy Act     | No               |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco/EMC Basic;Veeder Root/8484 Series PLLD |                          |                               |                |                  |

Facility Summary in Stillwater County in the City of Columbus

Location: GITS CONOCO  
740 E Pike Ave  
Columbus, MT 59019 Stillwater

System Facility ID:48-07859

Facility Code: 28599  
Last Inspected On: 07/11/2022  
Operating Permit Renewal Date: 10/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

|                                  |            |
|----------------------------------|------------|
| Owner Operator Contact: Gits Inc | 4063224111 |
|----------------------------------|------------|

Owner/Operator: Gits Inc

Gary Woltermann, UST Class A Operator  
Gary Woltermann, UST Class B Global Operator  
Tracy Gernant, UST Class A Operator  
Tracy Gernant, UST Class B Global Operator

|             |                  |                    |            |                          |            |                               |  |                          |                               |                |                                |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|-------------------------------|----------------|--------------------------------|
| Tank Code   | 01               | Tank Age           | 43         | Tank Installed Date      | 05/08/1979 | Tank Material                 | Cathodically Protected Steel   | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 3209             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             | Lined Interior/Impressed Current                                       | Piping Construction      | None                          | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector  | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current              |
| Product     | Gasoline         | PLLD Test Date     | 07/11/2022 | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                             |
| Capacity    | 10000            | ATG Test Date      | 07/11/2022 | Line Tightness Test Date | 07/09/2022 | Secondary Tank Leak Detection |  | Secondary Pipe Detection |                               | Energy Act     | No                             |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD |                          |                               |                |                                |
| Tank Code   | 02               | Tank Age           | 43         | Tank Installed Date      | 05/08/1979 | Tank Material                 | Cathodically Protected Steel   | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 3210             | Spill Test Date    | 07/11/2022 | Piping Installed Date    |            | Tank Construction             | Lined Interior/Impressed Current                                       | Piping Construction      | None                          | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector  | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current              |
| Product     | Gasoline         | PLLD Test Date     | 07/11/2022 | Tank/Piping CP Test Date | 07/11/2022 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                             |
| Capacity    | 10000            | ATG Test Date      | 07/11/2022 | Line Tightness Test Date | 07/11/2022 | Secondary Tank Leak Detection |  | Secondary Pipe Detection |                               | Energy Act     | No                             |
|             |                  | Overfill Test Date | 07/11/2022 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD |                          |                               |                |                                |

Facility Summary in Stillwater County in the City of Columbus

Location: TOWN PUMP INC COLUMBUS UST  
602 E 8th Ave N  
Columbus, MT 59019 Stillwater

Facility Code: 28607  
Last Inspected On: 08/10/2021  
System Facility ID:48-08691  
Operating Permit Renewal Date: 11/18/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

|  |  |  |  |            |  |  |  |
|--|--|--|--|------------|--|--|--|
| Owner Operator Contact: Columbus 1 Town Pump LLC |  |  |  | 4064976700 |  |  |  |
| Operator Contact: Trent Biggers                  |  |  |  |            |  |  |  |

Owner/Operator: Columbus 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

|             |                  |                    |            |                          |            |                               |                                      |                          |                                      |                |                   |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|-------------------|
| Tank Code   | 03               | Tank Age           | 38         | Tank Installed Date      | 05/01/1984 | Tank Material                 | Cathodically Protected Steel         | Piping Material          | Fiberglass Reinforced Plastic        | Overfill Types | Flapper Valve     |
| Tag Number  | 2646             | Spill Test Date    | 06/10/2021 | Piping Installed Date    |            | Tank Construction             | Lined Interior/Impressed Current     | Piping Construction      | None                                 | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized                          | CP Met Types   | Impressed Current |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date | 06/10/2021 | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Statistical Inventory Reconciliation | Vapor Recovery | No                |
| Capacity    | 6000             | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                      | Secondary Pipe Detection |                                      | Energy Act     | No                |
|             |                  | Overfill Test Date | 08/12/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |                                      |                |                   |
| Tank Code   | 06               | Tank Age           | 38         | Tank Installed Date      | 09/01/1984 | Tank Material                 | Cathodically Protected Steel         | Piping Material          | Fiberglass Reinforced Plastic        | Overfill Types | Flapper Valve     |
| Tag Number  | 2647             | Spill Test Date    | 08/12/2021 | Piping Installed Date    |            | Tank Construction             |                                      | Piping Construction      | None                                 | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized                          | CP Met Types   | Galvanic          |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date | 06/10/2021 | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Statistical Inventory Reconciliation | Vapor Recovery | No                |
| Capacity    | 12000            | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                      | Secondary Pipe Detection |                                      | Energy Act     | No                |
|             |                  | Overfill Test Date | 08/12/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |                                      |                |                   |
| Tank Code   | 07               | Tank Age           | 34         | Tank Installed Date      | 12/29/1988 | Tank Material                 | Cathodically Protected Steel         | Piping Material          | Fiberglass Reinforced Plastic        | Overfill Types | Flapper Valve     |

|             |                  |                    |            |                          |            |                               |                                      |                          |   |                |               |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|---|----------------|---------------|
| Tag Number  | 2648             | Spill Test Date    | 06/10/2021 | Piping Installed Date    |            | Tank Construction             |                                      | Piping Construction      | None  | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized   | CP Met Types   | Galvanic      |
| Product     | Gasoline         | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date | 06/10/2021 | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Statistical Inventory Reconciliation                            | Vapor Recovery | No            |
| Capacity    | 12000            | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                      | Secondary Pipe Detection |   | Energy Act     | No            |
|             |                  | Overfill Test Date | 08/12/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |   |                |               |
| Tank Code   | 08               | Tank Age           | 34         | Tank Installed Date      | 11/01/1988 | Tank Material                 | Cathodically Protected Steel         | Piping Material          | Fiberglass Reinforced Plastic                                   | Overfill Types | Flapper Valve |
| Tag Number  | 2649             | Spill Test Date    | 08/12/2021 | Piping Installed Date    |            | Tank Construction             |                                      | Piping Construction      | None  | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized   | CP Met Types   | Galvanic      |
| Product     | Gasoline         | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date | 06/10/2021 | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Approved Remote Monitoring;Statistical Inventory Reconciliation | Vapor Recovery | No            |
| Capacity    | 12000            | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                      | Secondary Pipe Detection |   | Energy Act     | No            |
|             |                  | Overfill Test Date | 08/12/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |   |                |               |
| Tank Code   | 09               | Tank Age           | 34         | Tank Installed Date      | 11/01/1988 | Tank Material                 | Cathodically Protected Steel         | Piping Material          | Fiberglass Reinforced Plastic                                   | Overfill Types | Flapper Valve |
| Tag Number  | 2650             | Spill Test Date    | 08/12/2021 | Piping Installed Date    |            | Tank Construction             |                                      | Piping Construction      | None  | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized   | CP Met Types   | Galvanic      |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date | 06/10/2021 | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Statistical Inventory Reconciliation                            | Vapor Recovery | No            |
| Capacity    | 12000            | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                      | Secondary Pipe Detection |   | Energy Act     | No            |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |   |                |               |
| Tank Code   | 10               | Tank Age           | 34         | Tank Installed Date      | 11/01/1988 | Tank Material                 | Cathodically Protected Steel         | Piping Material          | Fiberglass Reinforced Plastic                                   | Overfill Types | Flapper Valve |
| Tag Number  | 2651             | Spill Test Date    | 08/12/2021 | Piping Installed Date    |            | Tank Construction             |                                      | Piping Construction      | None  | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized   | CP Met Types   | Galvanic      |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date | 06/10/2021 | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Statistical Inventory Reconciliation                            | Vapor Recovery | No            |

|             |                  |                    |            |                          |            |                               |                                      |                          |                                      |                |                  |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Capacity    | 12000            | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                      | Secondary Pipe Detection |                                      | Energy Act     | No               |
|             |                  | Overfill Test Date | 08/12/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |                                      |                |                  |
| Tank Code   | 11               | Tank Age           | 23         | Tank Installed Date      | 06/25/1999 | Tank Material                 | Fiberglass Reinforced Plastic        | Piping Material          | Flexible Plastic                     | Overfill Types | Flapper Valve    |
| Tag Number  | 4064             | Spill Test Date    | 08/12/2021 | Piping Installed Date    | 06/16/2020 | Tank Construction             | Double-Walled                        | Piping Construction      | Double Walled                        | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 06/10/2021 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized                          | CP Met Types   | Non-corrodible   |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Continuous Interstitial Monitoring   | Vapor Recovery | No               |
| Capacity    | 15000            | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection | Continuous Interstitial Monitoring   | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act     | No               |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |                                      |                |                  |
| Tank Code   | 12               | Tank Age           | 23         | Tank Installed Date      | 06/25/1999 | Tank Material                 | Fiberglass Reinforced Plastic        | Piping Material          | Flexible Plastic                     | Overfill Types | Ball Float Valve |
| Tag Number  | 4065             | Spill Test Date    | 06/10/2021 | Piping Installed Date    | 06/16/2020 | Tank Construction             | Double-Walled                        | Piping Construction      | Double Walled                        | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 06/10/2021 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized                          | CP Met Types   | Non-corrodible   |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Continuous Interstitial Monitoring   | Vapor Recovery | No               |
| Capacity    | 8000             | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection | Continuous Interstitial Monitoring   | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act     | No               |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |                                      |                |                  |
| Tank Code   | 13               | Tank Age           | 23         | Tank Installed Date      | 06/25/1999 | Tank Material                 | Fiberglass Reinforced Plastic        | Piping Material          | Flexible Plastic                     | Overfill Types | Ball Float Valve |
| Tag Number  | 4066             | Spill Test Date    | 06/10/2021 | Piping Installed Date    | 06/16/2020 | Tank Construction             | Double-Walled                        | Piping Construction      | Double Walled                        | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 06/10/2021 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector        | Piping Type              | Pressurized                          | CP Met Types   | Non-corrodible   |
| Product     | Diesel           | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Statistical Inventory Reconciliation | Primary Pipe Detection   | Continuous Interstitial Monitoring   | Vapor Recovery | No               |
| Capacity    | 8000             | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection | Continuous Interstitial Monitoring   | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act     | No               |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450         |                          |                                      |                |                  |



|             |                     |                    |            |                          |            |                               |   |                          |                                      |                |                  |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code   | 14                  | Tank Age           | 18         | Tank Installed Date      | 12/30/2004 | Tank Material                 | Fiberglass Reinforced Plastic                                   | Piping Material          | Fiberglass Reinforced Plastic        | Overfill Types | Ball Float Valve |
| Tag Number  | 4933                | Spill Test Date    | 08/12/2021 | Piping Installed Date    |            | Tank Construction             | Double-Walled   | Piping Construction      | Double Walled                        | AST            | No               |
| Tank Status | Currently in Use    | MLLD Test Date     |            | Sump Tightness Test Date | 06/10/2021 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                                   | Piping Type              | Pressurized                          | CP Met Types   | Non-corrodible   |
| Product     | Gasoline            | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Statistical Inventory Reconciliation                            | Primary Pipe Detection   | Statistical Inventory Reconciliation | Vapor Recovery | No               |
| Capacity    | 20000               | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection | Continuous Interstitial Monitoring                              | Secondary Pipe Detection | Continuous Interstitial Monitoring   | Energy Act     | No               |
|             |                     | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450                                    |                          |                                      |                |                  |
| Tank Code   | 15                  | Tank Age           | 9          | Tank Installed Date      | 10/01/2013 | Tank Material                 | Fiberglass Reinforced Plastic                                   | Piping Material          | Fiberglass Reinforced Plastic        | Overfill Types |                  |
| Tag Number  | 5437                | Spill Test Date    |            | Piping Installed Date    | 08/25/2013 | Tank Construction             | Double-Walled   | Piping Construction      | None                                 | AST            | No               |
| Tank Status | Currently in Use    | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     |   | Piping Type              | Pressurized                          | CP Met Types   |                  |
| Product     | DEF (Not Regulated) | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Not Listed  | Primary Pipe Detection   | Not Listed                           | Vapor Recovery | No               |
| Capacity    | 10000               | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection |   | Secondary Pipe Detection | Not Listed                           | Energy Act     | Yes              |
|             |                     | Overfill Test Date |            |                          |            | ATG Type                      |   |                          |                                      |                |                  |
| Tank Code   | 16                  | Tank Age           | 2          | Tank Installed Date      | 06/16/2020 | Tank Material                 | Fiberglass Reinforced Plastic                                   | Piping Material          | Flexible Plastic                     | Overfill Types | Flapper Valve    |
| Tag Number  | 5968                | Spill Test Date    | 06/10/2021 | Piping Installed Date    | 06/16/2020 | Tank Construction             | Double-Walled   | Piping Construction      | Double Walled                        | AST            | No               |
| Tank Status | Currently in Use    | MLLD Test Date     |            | Sump Tightness Test Date | 06/10/2021 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                                   | Piping Type              | Pressurized                          | CP Met Types   | Non-corrodible   |
| Product     | Gasoline            | PLLD Test Date     | 08/04/2022 | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                              | Primary Pipe Detection   | Continuous Interstitial Monitoring   | Vapor Recovery | Yes              |
| Capacity    | 8000                | ATG Test Date      | 08/04/2022 | Line Tightness Test Date |            | Secondary Tank Leak Detection | Statistical Inventory Reconciliation                            | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act     | Yes              |
|             |                     | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root;/Gilbarco-Veeder Root/TLS-450;Veeder Root/ |                          |                                      |                |                  |
| Tank Code   | 17                  | Tank Age           | 0          | Tank Installed Date      |            | Tank Material                 | Fiberglass Reinforced Plastic                                   | Piping Material          | Fiberglass Reinforced Plastic        | Overfill Types |                  |
| Tag Number  | 5969                | Spill Test Date    |            | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      |                                      | AST            | No               |
| Tank Status | Currently in Use    | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     |   | Piping Type              | Pressurized                          | CP Met Types   |                  |

|          |                     |                    |  |                          |  |                               |  |                          |  |                |    |
|----------|---------------------|--------------------|--|--------------------------|--|-------------------------------|--|--------------------------|--|----------------|----|
| Product  | DEF (Not Regulated) | PLLD Test Date     |  | Tank/Piping CP Test Date |  | Primary Tank Leak Detection   |  | Primary Pipe Detection   |  | Vapor Recovery | No |
| Capacity | 10000               | ATG Test Date      |  | Line Tightness Test Date |  | Secondary Tank Leak Detection |  | Secondary Pipe Detection |  | Energy Act     | No |
|          |                     | Overfill Test Date |  |                          |  | ATG Type                      |  |                          |  |                |    |

Facility Summary in Stillwater County in the City of Fishtail

Location: FISHTAIL BASIN RANCH  
633 Fiddler Creek Rd  
Fishtail, MT 59028-8021 Stillwater

System Facility ID:56-13917

Facility Code: 30587  
Last Inspected On: 11/10/2020  
Operating Permit Renewal Date: 01/28/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Francis Abbott;Francis Abbott Jr6103539700

Operator Contact: Francis Abbott6103539700

Owner/Operator: Francis Abbott

Owner/Operator: Francis H Abbott Jr

Francis Abbott, UST Class A Operator  
Francis Abbott, UST Class B Operator

|             |                  |                    |    |                          |            |                               |                                    |                          |                                    |                |                |
|-------------|------------------|--------------------|----|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code   | S1               | Tank Age           | 23 | Tank Installed Date      | 03/01/1999 | Tank Material                 | Steel Clad                         | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve  |
| Tag Number  | 4400             | Spill Test Date    |    | Piping Installed Date    |            | Tank Construction             | Double-Walled                      | Piping Construction      | Double Walled                      | AST            | No             |
| Tank Status | Currently in Use | MLLD Test Date     |    | Sump Tightness Test Date | 11/10/2020 | Catastrophic L.D Type 3.0     | Continuous Interstitial Monitoring | Piping Type              | U.S. Suction                       | CP Met Types   | Non-corrodible |
| Product     | Heating Oil      | PLLD Test Date     |    | Tank/Piping CP Test Date | 12/13/2011 | Primary Tank Leak Detection   | Manual Interstitial Monitoring     | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No             |
| Capacity    | 4000             | ATG Test Date      |    | Line Tightness Test Date |            | Secondary Tank Leak Detection |                                    | Secondary Pipe Detection | Manual Interstitial Monitoring     | Energy Act     | No             |
|             |                  | Overfill Test Date |    |                          |            | ATG Type                      |                                    |                          |                                    |                |                |

Facility Summary in Stillwater County in the City of Fishtail

Location: FISHTAIL GENERAL STORE  
35 W Main St  
Fishtail, MT 59028-0040 Stillwater

System Facility ID:48-03599

Facility Code: 28556  
Last Inspected On: 10/13/2021  
Operating Permit Renewal Date: 03/07/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fishtail General Store

4063284260

Operator Contact: Katy Martin

Owner/Operator: Fishtail General Store

Katy Martin, UST Class A Operator

Katy Martin, UST Class B Operator

|             |                  |                    |            |                          |            |                               |   |                          |                  |                |                  |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|------------------|
| Tank Code   | 02               | Tank Age           | 29         | Tank Installed Date      | 05/01/1993 | Tank Material                 | Steel Clad                                | Piping Material          | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 1086             | Spill Test Date    | 10/13/2021 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | Double Walled    | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                              | Piping Type              | Safe Suction     | CP Met Types   | Non-corrodible   |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date | 09/25/2015 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   |                  | Vapor Recovery | No               |
| Capacity    | 1000             | ATG Test Date      | 10/13/2021 | Line Tightness Test Date |            | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                  | Energy Act     | No               |
|             |                  | Overfill Test Date | 10/13/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                  |                |                  |
| Tank Code   | 03               | Tank Age           | 29         | Tank Installed Date      | 05/01/1993 | Tank Material                 | Steel Clad                                | Piping Material          | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number  | 1087             | Spill Test Date    | 10/13/2021 | Piping Installed Date    |            | Tank Construction             |   | Piping Construction      | Double Walled    | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                              | Piping Type              | Safe Suction     | CP Met Types   | Non-corrodible   |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date | 09/25/2015 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                | Primary Pipe Detection   |                  | Vapor Recovery | No               |
| Capacity    | 1002             | ATG Test Date      | 10/13/2021 | Line Tightness Test Date |            | Secondary Tank Leak Detection |   | Secondary Pipe Detection |                  | Energy Act     | No               |
|             |                  | Overfill Test Date | 10/13/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC |                          |                  |                |                  |

Facility Summary in Stillwater County in the City of Fishtail

Location: NYE TRADING POST  
1997 Nye Rd  
Fishtail, MT 59028 Stillwater

System Facility ID:48-09647

Facility Code: 28616  
Last Inspected On: 10/13/2021  
Operating Permit Renewal Date: 03/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Chance Kukowski;Nye MT LLC

4063286262;7203833694

|                   |              |            |
|-------------------|--------------|------------|
| Operator Contact: | Heath Benson | 7203833694 |
|-------------------|--------------|------------|

Owner/Operator: Chance Kukowski

Owner/Operator: Nye MT LLC

Heath Benson, UST Class A Operator

Heath Benson, UST Class B Global Operator

|             |                        |                    |            |                          |            |                               |                              |                          |                               |                |               |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tank Code   | 03                     | Tank Age           | 29         | Tank Installed Date      | 10/01/1993 | Tank Material                 | Cathodically Protected Steel | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number  | 1296                   | Spill Test Date    | 10/13/2021 | Piping Installed Date    |            | Tank Construction             |                              | Piping Construction      | None                          | AST            | No            |
| Tank Status | Currently in Use       | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                 | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic      |
| Product     | Gasoline               | PLLD Test Date     |            | Tank/Piping CP Test Date | 10/13/2021 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   |                               | Vapor Recovery | No            |
| Capacity    | 1000                   | ATG Test Date      | 10/13/2021 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                              | Secondary Pipe Detection |                               | Energy Act     | No            |
|             |                        | Overfill Test Date | 10/13/2021 |                          |            | ATG Type                      | Veeder Root/TLS-300          |                          |                               |                |               |
| Tank Code   | 04                     | Tank Age           | 29         | Tank Installed Date      | 10/01/1993 | Tank Material                 | Cathodically Protected Steel | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number  | 1297                   | Spill Test Date    |            | Piping Installed Date    |            | Tank Construction             |                              | Piping Construction      | None                          | AST            | No            |
| Tank Status | Temporarily Out of Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                 | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic      |
| Product     | Diesel                 | PLLD Test Date     |            | Tank/Piping CP Test Date | 10/13/2021 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   |                               | Vapor Recovery | No            |
| Capacity    | 1000                   | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection |                              | Secondary Pipe Detection |                               | Energy Act     | No            |
|             |                        | Overfill Test Date |            |                          |            | ATG Type                      | Veeder Root/TLS-300          |                          |                               |                |               |

Facility Summary in Stillwater County in the City of Fishtail

Location: TIPPET RISE COTTONWOOD SITE  
96 S Grove Creek Rd  
Fishtail, MT 59028 Stillwater

System Facility ID:60-15267

Facility Code: 30980  
Last Inspected On: 09/14/2020  
Operating Permit Renewal Date: 10/16/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tippet Rise Cottonwood Site

4062559287

Operator Contact: Carl Mayer;Christopher Castillo;Dan Luttschwager;Joshua Boyce 2076206273;4063287820;4066207404;4068600947

Owner/Operator: Tippet Rise Cottonwood Site

Carl Mayer, UST Class A Operator  
Carl Mayer, UST Class B Global Operator  
Christopher Castillo, UST Class A Operator  
Christopher Castillo, UST Class B Operator  
Dan Luttschwager, UST Class A Operator  
Joshua Boyce, UST Class A Operator  
Joshua Boyce, UST Class B Global Operator

|             |                  |                    |   |                          |            |                               |                                    |                          |                                    |                |                  |
|-------------|------------------|--------------------|---|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code   | 01               | Tank Age           | 6 | Tank Installed Date      | 10/07/2016 | Tank Material                 | Fiberglass Reinforced Plastic      | Piping Material          | Flexible Plastic                   | Overfill Types | High Level Alarm |
| Tag Number  | 5618             | Spill Test Date    |   | Piping Installed Date    | 10/07/2016 | Tank Construction             | Double-Walled                      | Piping Construction      | Double Walled                      | AST            | No               |
| Tank Status | Currently in Use | MLLD Test Date     |   | Sump Tightness Test Date | 09/30/2020 | Catastrophic L.D Type 3.0     | Continuous Interstitial Monitoring | Piping Type              | U.S. Suction                       | CP Met Types   | Non-corrodible   |
| Product     | Diesel           | PLLD Test Date     |   | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No               |
| Capacity    | 1000             | ATG Test Date      |   | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2         | Secondary Pipe Detection |                                    | Energy Act     | Yes              |
|             |                  | Overfill Test Date |   |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-300       |                          |                                    |                |                  |

Facility Summary in Stillwater County in the City of Park City

Location: KWIK STOP INC  
1 N Clark St  
Park City, MT 59063 Stillwater

System Facility ID:48-06610

Facility Code: 28591  
Last Inspected On: 10/07/2021  
Operating Permit Renewal Date: 03/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Margaret Keating 4066332730

Operator Contact: Margaret Keating 4066332730

Owner/Operator: Margaret Keating

Margaret Keating, UST Class A Operator

Margaret Keating, UST Class B Operator

|             |                  |                    |            |                          |            |                               |                              |                          |                               |                |               |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------|--------------------------|-------------------------------|----------------|---------------|
| Tank Code   | 03               | Tank Age           | 25         | Tank Installed Date      | 05/05/1997 | Tank Material                 | Cathodically Protected Steel | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number  | 1507             | Spill Test Date    | 10/07/2021 | Piping Installed Date    |            | Tank Construction             |                              | Piping Construction      | None                          | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                 | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic      |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date | 05/10/2021 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   |                               | Vapor Recovery | No            |
| Capacity    | 8000             | ATG Test Date      | 10/07/2021 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                              | Secondary Pipe Detection |                               | Energy Act     | No            |
|             |                  | Overfill Test Date | 10/07/2021 |                          |            | ATG Type                      | Veeder Root/TLS-300          |                          |                               |                |               |
| Tank Code   | 04               | Tank Age           | 25         | Tank Installed Date      | 05/05/1997 | Tank Material                 | Cathodically Protected Steel | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number  | 1508             | Spill Test Date    | 10/07/2021 | Piping Installed Date    |            | Tank Construction             |                              | Piping Construction      | None                          | AST            | No            |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Not Required                 | Piping Type              | Safe Suction                  | CP Met Types   | Galvanic      |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date | 05/10/2021 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2   | Primary Pipe Detection   |                               | Vapor Recovery | No            |
| Capacity    | 4000             | ATG Test Date      | 10/07/2021 | Line Tightness Test Date |            | Secondary Tank Leak Detection |                              | Secondary Pipe Detection |                               | Energy Act     | No            |
|             |                  | Overfill Test Date | 10/07/2021 |                          |            | ATG Type                      | Veeder Root/TLS-300          |                          |                               |                |               |

Facility Summary in Stillwater County in the City of Park City

Location: ZIP TRIP 50  
EXIT 426 AND I-90  
Park City, MT 59063 Stillwater

System Facility ID:48-08910

Facility Code: 28609  
Last Inspected On: 05/10/2019  
Operating Permit Renewal Date: 10/21/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

|                         |                          |            |
|-------------------------|--------------------------|------------|
| Owner Operator Contact: | CHS Inc Spokane Valley   | 5095357701 |
| Operator Contact:       | Jim Alford;Pete Nussbaum | 5095367418 |
| Owner/Operator:         | CHS Inc Spokane Valley   |            |

Darcy Ziegler, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Pete Nussbaum, UST Class A Operator

Pete Nussbaum, UST Class B Global Operator  
Robert Hays, UST Class B Operator

|             |                     |                    |            |                          |            |                               |  |                          |                                    |                |                                |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code   | 17                  | Tank Age           | 7          | Tank Installed Date      | 06/01/2015 | Tank Material                 | Fiberglass Reinforced Plastic                              | Piping Material          | Flexible Plastic                   | Overfill Types |                                |
| Tag Number  | 5599                | Spill Test Date    |            | Piping Installed Date    |            | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Other               | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Continuous Interstitial Monitoring                         | Piping Type              | Not Listed                         | CP Met Types   |                                |
| Product     | DEF (Not Regulated) | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No                             |
| Capacity    | 6000                | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection |  | Secondary Pipe Detection | Not Listed                         | Energy Act     | No                             |
|             |                     | Overfill Test Date |            |                          |            | ATG Type                      |  |                          |                                    |                |                                |
| Tank Code   | 18                  | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5954                | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use    | MLLD Test Date     |            | Sump Tightness Test Date | 10/25/2019 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Gasoline            | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | Yes                            |
| Capacity    | 20000               | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |
|             |                     | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |
| Tank Code   | 19                  | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Fiberglass Reinforced Plastic      | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5955                | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use    | MLLD Test Date     |            | Sump Tightness Test Date | 10/25/2019 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Gasoline            | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | Yes                            |
| Capacity    | 10000               | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |

|             |                  |                    |            |                          |            |                               |  |                          |                                    |                |                                |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|--------------------------------|
|             |                  | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |
| Tank Code   | 20               | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5957             | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 10/25/2019 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Gasoline         | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | Yes                            |
| Capacity    | 15000            | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |
|             |                  | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |
| Tank Code   | 21               | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5958             | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No                             |
| Capacity    | 15000            | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |
|             |                  | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |
| Tank Code   | 22               | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5959             | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 10/25/2019 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No                             |



|             |                  |                    |            |                          |            |                               |  |                          |                                    |                |                                |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|--------------------------------|
| Capacity    | 20000            | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |
|             |                  | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |
| Tank Code   | 23               | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5960             | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 10/25/2019 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Diesel, Dyed     | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No                             |
| Capacity    | 10000            | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |
|             |                  | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |
| Tank Code   | 24               | Tank Age           | 3          | Tank Installed Date      | 10/25/2019 | Tank Material                 | Steel Clad   | Piping Material          | Flexible Plastic                   | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number  | 5961             | Spill Test Date    | 08/26/2021 | Piping Installed Date    | 10/25/2019 | Tank Construction             | Double-Walled  | Piping Construction      | Double Walled                      | AST            | No                             |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date | 10/25/2019 | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                              | Piping Type              | Pressurized                        | CP Met Types   | Non-corrodible                 |
| Product     | Diesel           | PLLD Test Date     |            | Tank/Piping CP Test Date |            | Primary Tank Leak Detection   | Continuous Interstitial Monitoring                         | Primary Pipe Detection   | Continuous Interstitial Monitoring | Vapor Recovery | No                             |
| Capacity    | 30000            | ATG Test Date      |            | Line Tightness Test Date |            | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2                                 | Secondary Pipe Detection | ELLD 0.2                           | Energy Act     | Yes                            |
|             |                  | Overfill Test Date | 08/26/2021 |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD |                          |                                    |                |                                |

**Facility Summary in Stillwater County in the City of Reed Point**

**Location:** VALLEY FARMERS SUPPLY SURE STOP  
4 N Division St  
Reed Point, MT 59069 Stillwater

System Facility ID:48-01521

**Facility Code:** 28529  
**Last Inspected On:** 03/31/2020  
**Operating Permit Renewal Date:** 09/04/2023

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Julie Pratton;Valley Farmers Supply

4069673100

Operator Contact: Elisha Lewis;Scott Black;Steven Shelton

4063200055;4063225214;4069673100

Owner/Operator: Julie L Pratton

Owner/Operator: Valley Farmers Supply

- Elisha Lewis, UST Class A Operator
- Elisha Lewis, UST Class B Global Operator
- Scott Black, UST Class A Operator
- Scott Black, UST Class B Global Operator
- Steven Shelton, UST Class A Operator

|             |                  |                    |            |                          |            |                               |  |                          |                               |                |                   |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|-------------------------------|----------------|-------------------|
| Tank Code   | 01               | Tank Age           | 36         | Tank Installed Date      | 12/10/1986 | Tank Material                 | Bare Steel   | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve     |
| Tag Number  | 3303             | Spill Test Date    | 03/30/2021 | Piping Installed Date    |            | Tank Construction             |  | Piping Construction      | None                          | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                          | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current |
| Product     | Gasoline         | PLLD Test Date     | 03/31/2020 | Tank/Piping CP Test Date | 03/31/2020 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                             | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                |
| Capacity    | 6000             | ATG Test Date      |            | Line Tightness Test Date | 11/08/2019 | Secondary Tank Leak Detection |  | Secondary Pipe Detection |                               | Energy Act     | No                |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/ |                          |                               |                |                   |
| Tank Code   | 02               | Tank Age           | 36         | Tank Installed Date      | 12/10/1986 | Tank Material                 | Bare Steel   | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve     |
| Tag Number  | 3304             | Spill Test Date    | 03/30/2021 | Piping Installed Date    |            | Tank Construction             |  | Piping Construction      | None                          | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                          | Piping Type              | Pressurized                   | CP Met Types   | Impressed Current |
| Product     | Gasoline         | PLLD Test Date     | 03/31/2020 | Tank/Piping CP Test Date | 03/31/2020 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                             | Primary Pipe Detection   | ELLD 0.2                      | Vapor Recovery | No                |
| Capacity    | 6000             | ATG Test Date      |            | Line Tightness Test Date | 02/19/2020 | Secondary Tank Leak Detection |  | Secondary Pipe Detection |                               | Energy Act     | No                |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/ |                          |                               |                |                   |
| Tank Code   | 03               | Tank Age           | 36         | Tank Installed Date      | 12/10/1986 | Tank Material                 | Bare Steel   | Piping Material          | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve     |

|             |                  |                    |            |                          |            |                               |  |                          |             |                |                   |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|-------------|----------------|-------------------|
| Tag Number  | 3305             | Spill Test Date    | 03/30/2021 | Piping Installed Date    |            | Tank Construction             |  | Piping Construction      | None        | AST            | No                |
| Tank Status | Currently in Use | MLLD Test Date     |            | Sump Tightness Test Date |            | Catastrophic L.D Type 3.0     | Electronic Line Leak Detector                          | Piping Type              | Pressurized | CP Met Types   | Impressed Current |
| Product     | Diesel           | PLLD Test Date     | 03/31/2020 | Tank/Piping CP Test Date | 03/31/2020 | Primary Tank Leak Detection   | Automatic Tank Gauging 0.2                             | Primary Pipe Detection   | ELLD 0.2    | Vapor Recovery | No                |
| Capacity    | 4000             | ATG Test Date      |            | Line Tightness Test Date | 12/27/2019 | Secondary Tank Leak Detection |  | Secondary Pipe Detection |             | Energy Act     | No                |
|             |                  | Overfill Test Date |            |                          |            | ATG Type                      | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/ |                          |             |                |                   |